



LICENCE

to use the European Mark



Licence No.: **163-022**

Date of issue: Wien, 2021 06 14

OVE the Austrian Electrotechnical Association as signatory to the **"Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards"** hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licenceholder: **Electro Terminal GmbH & Co KG**
Archenweg 58
6020 Innsbruck
Austria

Product: **Screwless-type clamping units**

Trade Mark:

Series/Type: **SLC 2, SLC 3, SLC 5**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

Digitally signed by M. Neugebauer
on behalf of T. Neumayer
Email=m.neugebauer@ove.at


Dipl.-Ing. T. Neumayer

Akkreditierung Austria
A
0902
ISO/IEC 17065

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

| | |
|---|--|
| <i>Hersteller</i> <i>Manufacturer</i> | Electro Terminal GmbH & Co KG Archenweg 58 6020 Innsbruck Austria |
| <i>Fertigungsstätte(n)</i> <i>Factory location(s)</i> | Electro Terminal GmbH & Co KG Archenweg 58 6020 Innsbruck Austria |
| <i>Typenbezeichnung</i> <i>Type reference</i> | SLC 2, SLC 3, SLC 5 |
| <i>Prüfbericht</i> <i>Test Report</i> | TGM-VA EE 38803 ECS 1 |
| <i>Nationale Bestimmung(en)</i> <i>National Standard(s)</i> | ÖVE/ÖNORM EN 60998-1:2005-05-01 ÖVE/ÖNORM EN 60998-2-2:2005-05-01 |
| <i>Europäischer Standard(en)</i> <i>European Standard(s)</i> | EN 60998-1:2004 EN 60998-2-2:2004 |
| <i>Ersatz für Zertifikat</i> <i>Superseded licence</i> | -- |
| <i>Anmerkung(en)</i> <i>Remark(s)</i> | -- |

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



| | |
|---|--|
| <i>Bemessungs-Isolationsspannung</i> <i>Rated insulation voltage</i> | AC/DC 450 V |
| <i>Bemessungs-Anschlußvermögen</i> <i>Rated connecting capacity</i> | 4 mm², Clamping range: 0,2 - 4 mm² and 0,14 mm² f |
| <i>Anzahl der Pole</i> <i>Number of poles</i> | 2 - 5 |
| <i>Umgebungstemperatur</i> <i>Ambient temperature</i> | T85 |
| <i>Leiterart</i> <i>Type of conductor</i> | rigid, flexible |
| <i>Beschreibung des Aufbaus</i> <i>Description of construction</i> | Connecting device with screwless-type clamping units; Material of terminal housing: Polycarbonate opaque or transparent. |
| <i>Zusatzinformation</i> <i>Additional information</i> | IP20, Test current according EN 60998-2-2:2004: 32 A Additional tests for 0,14 mm² according manufacturers specification. (test current 2 A) |

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

