



CERTIFICATE

including factory surveillance

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to apply the following marking to the listed products.

OVE Reg. Nr. 163-002

Certificate No.: **163-002-02**

Valid from: 2020 11 21
until: 2022 11 21

Company: **Electro Terminal GmbH & Co KG**
Archenweg 58
6020 Innsbruck
Austria

Product: **Screwless-type clamping units for luminaires**

The products submitted by the applicant were tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37751, TGM-VA EE 37751A**

Österreichischer Verband für Elektrotechnik
Head of Testing and Certification

Digitally signed by W. Martin
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 09 10



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

Electro Terminal GmbH & Co KG
Archenweg 58
6020 Innsbruck
Austria

Factory location(s):

Electro Terminal GmbH & Co KG
Archenweg 58
6020 Innsbruck
Austria

Tested and certified according to:

OVE EN 60598-1:2018-11-01 clause 3, 4, 7 (Annex V), 8, 9, 10, 11, 13 and 15
ÖVE/ÖNORM EN 60998-1:2005-05-01 clause 8, 14.101, 15, 16 and 18
ÖVE/ÖNORM EN 60998-2-2:2005-05-01 clause 8, 14.101, 15, 16 and 18

EN 60598-1:2015 + A1:2018 clause 3, 4, 7 (Annex V), 8, 9, 10, 11, 13 and 15
EN 60998-1:2004 clause 8, 14.101, 15, 16 and 18
EN 60998-2-2:2004 clause 8, 14.101, 15, 16 and 18

Product: Screwless-type clamping units for luminaires

Type designation:

Rating:

Trademark:

Electro-Terminal (ET)

SLK 7


Rated current: 16 A
Working voltage: 250 V / 400 V
T85; 5-pole
upper terminals: 0,5 - 2,5 mm²
lower terminals: 0,5 - 2,5 mm² s; 1,5 - 2,5 mm² r

OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

Type Code

SLK 7/5 (X) OF E-PIEC L-N-E-DA+-DA- (TXT)



OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

